

Virginia's Offshore Wind Resource: Size, Economics, and Future Development

Virginia Commission on Energy and Environment

Richmond, VA

18 August 2009



George Hagerman


VCERC Director of Research
Virginia Tech Advanced Research Institute
4300 Wilson Blvd., Suite 750
Arlington, VA 22203

Email: hagerman@vt.edu
Phone: 703-387-6030

Virginia's Realistic Near-Term Offshore Wind Development Potential



Greatest Near-Term Mid-Atlantic Offshore Wind Potential is off Dominion's VA-NC Service Area



- 5-Year Limited Lease Blocks for Data Collection
 - Existing 500 kV Substation
 - 100 ft. Depth Contour
 - Recreational Fishing Areas (VA to NJ only)
 - Highest Concentration of Dredge and Bottom Trawl Fishing*
- Wind Power Class
- 3
 - 4
 - 5
 - 6

*More than 100 days/yr.

Produced by TNC-VA (C. Bruce), 06/03/09

Data Sources: NREL, VCERC, MMS, NOAA, NJDEP, NMFS, USGS

GIS Analysis and Mapping of Resource

- Focus on 50 MMS lease blocks and avoid all excluded

Legend

- MMS Lease Blocks
- State Jurisdictional Limit (3nm)
- Territorial Sea Limit (12nm)
- Dumping Site (Dredged Material)
- 75.5 W longitude line
- 334.320 - Naval Restricted Area
- 334.390 - Firing Range
- 334.380 - Naval Firing Range
- R-6606 - VACAPES
- W-50A - VACAPES
- W-50B - VACAPES
- W-50C - VACAPES
- Precautionary Area
- Eastern Approach Separation State
- Eastern Approach Outbound Lane
- Eastern Approach Inbound Lane
- Southern Approach Outbound Lane
- Southern Approach Inbound Lane
- Shipping lanes ext


Wind class 5 6 no excl

Wind Class

- 5
- 6
- Land

Bathymetry - High Resolution meters

- >40m
- 35-40m
- 30-35m
- 25-30m
- 20-25m
- 15-20m
- 10-15m
- 5-10m
- 0-5m



MMS lease blocks are 4.8 km x 4.8 km, with each block having 7 x 7 turbines.

Turbines spaced 685 m apart (7.6 rotor diameters)

Each lease block could contain 49 turbines




= 147 MW per block with Vestas model V-90 3 MW

= 6.4 MW per km²




GIS layers and calculations by James Madison University

Class 6 Winds are Largely Beyond the Visual Horizon

Legend

-  MMS Lease Blocks
-  State Jurisdictional Limit (3nm)
-  Territorial Sea Limit (12nm)












-  Southern Approach Outbound Lane
-  Southern Approach Inbound Lane
-  Shipping lanes ext


Wind class 5 6 no excl

Wind Class

-  5
-  6
-  Land

Bathymetry - High Resolution meters

-  >40m
-  35-40m
-  30-35m
-  25-30m
-  20-25m
-  15-20m
-  10-15m
-  5-10m
-  0-5m



Meteorological Optical Range Table


Code No.	Weather	Distance
0	Dense fog	Less than 50
1	Thick fog	50 - 200 yards
2	Moderate	200 - 500 yards
3	Light fog	500 - 1000 yards
4	Thin fog	.5 - 1.0 nm
5	Haze	1.0 - 2.0 nm
6	Light Haze	2.0 - 5.5 nm
7	Clear	5.5 - 11.0 nm
8	Very Clear	11.0 - 27.0 nm
9	Exceptionally Clear	Over 27.0

Beyond the Territorial Sea Limit of 12 n.mi., turbines would be barely visible, and then only on the clearest days.

Total available area of Class 6 beyond 12 n.mi. is 575.6 sq.km (142,500 acres); could support 3,680 MW of wind capacity.


Preliminary GIS Calculations

- At density of 6.4 MW per km², could support ~4.5 GW, avoiding all excluded areas



Assuming capacity factors of 35% for Class 5 and 40% for Class 6, annual generation potential is ~5,500 and ~14,100 GWh/yr from Class 5 and Class 6 areas, respectively.


Near-Term Offshore Wind Generation Potential Compared with Virginia's Other Electricity Sources



Offshore Wind Project Layout and Construction



Typical Offshore Wind Farm Layout



Monopile Foundations Driven into Seabed and Transition Pieces Grouted on Top



Horns Rev 2-MW Turbines Installed Using Self-Propelled A2 SEA Vessels



North Hoyle 2-MW Turbines Installed Using Towed Seacore Jack-Up Rigs



Wind as Hedge Against Future Price Increases in PJM




PJM Energizes About One-Fifth of the U.S. Gross Domestic Product



6,038 transmission
substations

KEY STATISTICS

PJM member companies	390+
millions of people served	51
peak load in megawatts	135,000
MW of generating capacity	163,806
miles of transmission lines	56,070
GWh of annual energy	700,000
generation sources	1,271
square miles of territory	164,260
area served	13 states + DC



26% of generation in
Eastern Interconnection

23% of load in
Eastern Interconnection

19% of transmission assets
in Eastern Interconnection

19% of U.S. GDP produced in PJM

Financial Assumptions

- Taxes and depreciation
 - *Composite tax rate: 38.8% (35% Federal, 5.85% State)*
 - *General depreciation declining balance is used*
 - GDS life of 15 years for conventional fuels
 - GDS life of 5 years (bonus depreciation) for wind
- Project financing
 - *100% of the plant is financed up front*
 - 43.2% Debt and 56.8% Equity
 - Debt interest rate: 5.586%
 - Equity rate of return: 13.75% common, 7.174% preferred
 - Includes 3-year construction loan (7.5% debt rate)
 - *Debt is paid monthly, equity quarterly*
 - *Financing term: 25 years*
 - *Service life: 25 years for gas, wind; 50 years for coal*


Buckingham County Combined Cycle Gas-Fired Project

- Capital cost basis
 - *As published in PUE-2008-00014 (Filed 03/11/2008)*
 - *Plant Cost \$614 million*
 - *Transmission Cost \$5.1 million*
- 580 MW rated capacity
- 89.9% annual operational capacity factor
- Plant heat rate: 6.09 MMBtu per MWhr
- 25 plant operators
- Emissions
 - *CO₂ 1,829,088 ton/year*
 - *No_x 178 ton/year*
- Actual in-service date: 2011
(used 2012 for all projects)



Wise County Coal-Fired Project

- Capital cost basis
 - *As published in PUE-2007-00066 (Filed 03/31/2008) & PUE-2007-00111 (Filed 12/03/2007)*
 - *Plant Cost \$1.8 billion*
 - *Transmission Cost \$23 million*
- 585 MW rated capacity
- 98.9% annual operational capacity factor
- Plant heat rate: 10.00 MMBtu per MWhr
- Coal heat content: 15.4 MMBTU per short ton
- 75 plant operators
- Emissions
 - *CO₂ 4,838,060 ton/year*
 - *NO_x 1,755 ton/year*
 - *SO_x 3,009 ton/year*
- Actual in-service date: 2013
(used 2012 for all projects)



V90-3MW Offshore Wind Project


Capital cost estimated in March 2008 dollars using Virginia maritime supplier bids and published data

- *Plant cost at offshore busbar : \$ 1,748 million*
- *Transmission cost to Fentress : \$ 153 million*
- *Total plant investment : \$ 1,901 million (~ \$3,230 / kW)*

588 MW installed
rated capacity

38% annual
capacity factor


20% PJM
capacity factor




Projected Coal Prices by 2012

NYMEX Coal Futures — Central Appalachia


July 2000 — December 2013




Eastern Rail CSX Coal Swap - Forward Strip



New Offshore Wind Compared with New Coal



Delivered Coal Prices Already Seem to Exceed Projections




Source: Ventyx, Inc., The Velocity Suite from modeled data


Projected Natural Prices by 2012

NYMEX Natural Gas Futures — Henry Hub


July 2009 — December 2014



Henry Hub Natural Gas Swap - Forward Strip



New Offshore Wind Compared with New CCGT



NERA Study of Fossil Generation Portfolio in PJM

Issue No. 2
April 2009

NERA
Economic Consulting



Energy Market Insights

Valuing Fossil Fuel Generation Assets in a Green Economy

by James Heidell & Mike King

From the Editor

This second EMI focuses on the quantitative assessment of key risks affecting the valuation of electricity generation assets. Mike King and Jim Heidell outline the stochastic model NERA has developed to help investors gain insights into the critical valuation issues surrounding fossil fuel generation plants. Challenges for valuing fossil fuel plants will increase going forward as the result of the potential impact of greenhouse gas regulation and policies designed to encourage the development of renewable generating technology. These environmental policies are prominent in many jurisdictions world-wide, providing wide applicability for the techniques discussed in this edition.

—Ann Whitfield, Editor


NERA Study of Fossil Generation Portfolio in PJM

Case Study

The following case study highlights our assessment process for an actual portfolio of coal-fired and gas-peaking plants located in the PJM region. On a MW basis, the existing portfolio consists of approximately two-thirds coal-fired assets and one-third peaking assets. Our case study incorporates uncertainty related to fossil fuel prices, RPS standards, greenhouse gas regulations, load growth and power plant replacement costs. In the case study, each of the key variables had three associated forecasts. This created 729 potential permutations or cases.


PJM Long-Term Electricity Price Forecast

Figure 2. Distribution of On-Peak Prices



PJM Long-Term Electricity Price Forecast

Figure 3. Distribution of Off-Peak Prices



Anticipated Commercial Development Timetable



Development of Greater Gabbard: 504 MW (UK)

December 2003
• Fluor/Airtricity JV awarded 500MW Greater Gabbard Offshore Wind Farm Project



December 2004
• Grid Connection Offer received from National Grid for connection at Sizewell, Suffolk

October 2005
• Consents application submitted



February 2007
• All onshore and offshore consents received
• Siemens selected for wind turbines



May 2008
• Financial Close & Notice to Proceed

October 2003
• Bids submitted for UK Round 2



2004
• Conceptual design
• Offshore Site Surveys
• Environmental
• Geophysical

September 2005
• Met Mast installed



Summer 2006
• Offshore geotechnical survey



October 2007
• Project definition completed
• Estimate prepared

2.5 Year Build-Out

Onshore work starts: mid-2008

Offshore work starts: mid-2009

First phase power: mid-2010


Full project power: end 2011

FLUOR

From lease award to construction start = ~4.5 years

Development of Horns Rev II: 209 MW (Denmark)




Timetable for Horns Rev 2



From lease award to construction start = ~2.5 years

Construction of Horns Rev II: 209 MW (Denmark)

Horns Rev 2 – Plan for construction



From construction start to fully commissioned = 1.5 years

DONG
energy


US Offshore Wind Commercial Projects

US Offshore Wind Projects

Project	State	MW
Cape Wind	MA	468
Hull Municipal	MA	15
Patriot Renewables	MA	300
Rhode Island (OER)	RI	400
New Jersey (BPU)	NJ	350
Delmarva	DE	350
Southern Company	GA	10
W.E.S.T.	TX	150
Cuyahoga County	OH	20
Total MW		2,063

US projects in offshore Atlantic will require 1-2 years to obtain non-competitive commercial lease, 3-4 years to obtain competitive commercial lease. To this must be added 4-7 years for development and build-out of any large (350-500 MW) project.

VCERC has recommended that Governor form federal-state-local task force to guide MMS offshore wind leasing process such that projects can become operational at projected time of commercial viability, namely by 2017-2018



Thank You!



Any questions?

Email: hagerman@vt.edu